

FISP Permit

Foam Insulated Sandwich Panel Work

Scope

This Work Permit is required for any temporary procedure or operations being carried out on Foam Insulated Sandwich Panels (FISP), to ensure fire safety procedures are in place before work commences. The Work Permit should be applied to employees or contractors and completed signed documents to be kept in file for future reference.

In view of the combustible nature of the insulation core, any procedure involving the generation of heat, sparks or use of open flame (welding, grinding, cutting, high speed drilling etc.) should be forbidden on or in close proximity to the panels.

Responsibility

Facilities Manager or Supervisor

- Ensure the FISP Work Permit is in place and adhered to when work is to be carried out on or in close proximity (within 10 metres) to Foam Insulated Sandwich Panels or exposed foam linings
- Ensure employees and contractors understand the scope and intent of the procedure
- Ensure the work is fully risk assessed and appropriate safe working methods adopted
- Ensure contractors engaged to carry out work on site have provided proof of current and adequate levels of Public Liability Insurance cover prior to commencement of any work

Employees and Contractors

- Ensure employees and/or contractors involved in work have read, understood and fully adhere to the FISP Procedures, Precautions and Work Permit

Procedures and Precautions

- The FISP Work Permit should provide details of the area where the work is to be performed, the nature of the work, equipment to be used and who will perform the work

- The FISP Work Permit should be issued by a designated and trained person in authority – Facilities Manager, Supervisor or nominee
- The signed and authorised FISP Work Permit must be prominently displayed at the site of the work
- It is the responsibility of the person performing the work to ensure the FISP Work Permit has been completed and authorised prior to commencement of work.
- The following precautions should be reviewed and considered during the Risk Assessment stage prior to establishing the safe working methods to be adopted. If it is agreed by the Facilities Manager, Supervisor or nominated person that not all following precautions are required, they are to strike them out of the FISP Work Permit and initial the amendment before signing the document.
 - **NO HOT WORK** to be undertaken on or in vicinity of Foam Insulated Panels
 - Where panels need to be cut, only cold cutting methods such as shearing (hand operated tools), low speed drills or hand tools are used.
 - Secure fixings to panels using adhesives (water based where possible) or mechanical fasteners. Where flammable adhesives must be used, ensure that no hazardous ignition sources (i.e. battery chargers, electrical panels or spark producing equipment) are operating within the area (approximately 3 metres).
 - Smoking and other ignition sources are not permitted during work on the panels.
 - Pipe penetrations should be sealed with a metal facing mechanically clamped or riveted onto the metal face of the panel.
 - Dispose of any panel off-cuts immediately. Waste panel material (especially cores) should be disposed of outside the building in a suitable waste bin situated at least 10 metres from the building.
 - A suitable serviceable fire extinguisher or hose-reel should be available at all times during the work.
 - All other fire protection/detection equipment (sprinklers, hose-reels, hydrants, fire alarm) should be in good working order.
 - At the end of the work, ensure that any exposed core has been resealed with a metal capping.

For further information please contact your local AIG risk engineer.

Foam Insulated Sandwich Panel Work Permit

Before commencing work consider whether the job can be avoided.

When making penetrations through or undertaken cutting work involving Foam Insulated Sandwich Panels, it is important it is undertaken safely and the foam core not left exposed to avoid the risk of ignition and subsequent fire. Complying with this work permit will minimize the risk by ensuring the job is managed in a consistent manner in accordance with the necessary precautions.

Job Number:		
PERMIT DURATION (not to exceed one shift)		
Date:	Commencement Time:	Completion Time:
Work undertaken by:	<input type="checkbox"/> Employee <input type="checkbox"/> Contractor	
Location/Area:		
Work Involved:		
Equipment Used:		
Personnel Involved:		

Precautions Checklist			
<input type="checkbox"/>	No Hot Work to be undertaken	<input type="checkbox"/>	Operating equipment shut down & isolated
<input type="checkbox"/>	Sprinkler Protection in service	<input type="checkbox"/>	Automatic Fire Alarm in service
<input type="checkbox"/>	Fire extinguisher or Hose reel available	<input type="checkbox"/>	Personnel trained to use fire fighting equipment
<input type="checkbox"/>	Work area clear of debris, combustibles and flammable materials/liquids	<input type="checkbox"/>	Confined spaces checked for toxic and flammable gases, dust and oxygen levels.
<input type="checkbox"/>	Department manager/supervisor notified work to commence	<input type="checkbox"/>	All tools / equipment to be used checked and serviceable
<input type="checkbox"/>	Detail Special Precautions		

Authorisation	
Authorisation (Person authorizing the work)	Signed: _____ Print Name: _____
Work Acceptance (Person undertaking the work)	I have been briefed & understand the scope of the work to be performed, am aware of hazards present, the precautions necessary & agree to abide by these precautions. Signed: _____ Print Name: _____ Date: _____ Time: _____
Post Work Check (Person responsible for final checks)	Area checked and all penetrations sealed with no internal foam core exposed. Waste material has been removed and disposed securely outside building. Signed: _____ Print Name: _____ Date: _____ Time: _____

www.aig.co.uk

BELFAST

Forsyth House
Cromac Square
Belfast BT2 8LA
Tel: 02890 726002
Fax: 02890 726085

CROYDON

2-8 Altyre Road
Croydon, Surrey CR9 2LG
Tel: 020 8681 2556
Fax: 020 8680 7158

LEEDS

5th Floor Gallery House
123-131 The Headrow
Leeds LS1 5RD
Tel: 0113 242 1177
Fax: 0113 242 1746

MANCHESTER

4th Floor, 201 Deansgate
Manchester M3 3NW
Tel: 0161 832 8521
Fax: 0161 832 0149

BIRMINGHAM

Embassy House
60 Church Street
Birmingham B3 2DJ
Tel: 0121 236 9471
Fax: 0121 233 3597

GLASGOW

Centenary House
69 Wellington Street
Glasgow G2 6HJ
Tel: 0141 303 4400
Fax: 0141 303 4440

LONDON

58 Fenchurch Street
London EC3M 4AB
Tel: 020 7954 7000
Fax: 020 7954 7001

American International Group, Inc. (AIG) is a leading global insurance organisation. Founded in 1919, today AIG member companies provide a wide range of property casualty insurance, life insurance, retirement products, and other financial services to customers in more than 80 countries and jurisdictions. These diverse offerings include products and services that help businesses and individuals protect their assets, manage risks and provide for retirement security. AIG common stock is listed on the New York Stock Exchange and the Tokyo Stock Exchange.

Additional information about AIG can be found at www.aig.com and www.aig.com/strategyupdate | YouTube: www.youtube.com/aig | Twitter: @AIGinsurance | LinkedIn: <http://www.linkedin.com/company/aig>.

AIG is the marketing name for the worldwide property-casualty, life and retirement, and general insurance operations of American International Group, Inc. For additional information, please visit our website at www.aig.com. All products and services are written or provided by subsidiaries or affiliates of American International Group, Inc. Products or services may not be available in all countries, and coverage is subject to actual policy language. Non-insurance products and services may be provided by independent third parties.

American International Group UK Limited is registered in England: company number 10737370. Registered address: The AIG Building, 58 Fenchurch Street, London EC3M 4AB. American International Group UK Limited is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and Prudential Regulation Authority (FRN number 781109). This information can be checked by visiting the FS Register (www.fca.org.uk/register).

